G.R.S. IX—5]

Previous references. 1923-24 **File No.** 4-23

V.V. 4-23 Sl 70 & 72
V.V. 4-23 Sl 33 ---- 64 (V.V.)

Serial Nos. 106-109

Later references.

(12)

GENERAL AND REVENUE SECRETARIAT.

Serial Nos. ~~Four~~ (4) ✓

Part B for Dec. 1923

SUBJECT

Estimates for installee of 8 wall-slups between the Banquet Hall and the small dining room of Govt House.

Sl 109) To The private secy. to H.H. the Maharaja
The Chief Electrical Engineer in Mysore
The Comptroller to Govt.
No. C 9589-9/— dt 12-12-1923.

Sanctione d —

K. Govindaraya Iyer
13.12.1923

G. R. S. III.21

General and Revenue Secretariat.

V V. File No. 4 of 1923.

Serial No.	
106	From The Chief Electrical Engr No 3625 dt 4/12/23 Forwarding for sanction a revised estimate amounting to Rs 337/- on account of metalling eight wall lamps between the Banquet Hall and the small dining room of Govt House.
107	From The Chief Electrical Engr No 3626 dt 4/12/23 Forwarding for sanction an estimate for Rs 187/- for replacing the burnt out lamps and attending to the alterations in the various buildings at Ranchi.
108	From The Chief Electrical Engr No 3627 dt 4/12/23 Forwarding for sanction an estimate for Rs 45/- for wiring and installing call bells from Viceroy's room to his Valet's tent and from

NOTE—Contn. sheet.

3530

G. R. S. III-21

General and Revenue Secretariat.

VV File No. 4 of 1923

Serial No.

DEWAN'S OFFICE.
Recd. on DEC 10 1923
Reg. No. 3809

Viceroy's room to be made
Apartments in Rambagh.
Sube with a rough sanction
As the expenditure is
small it is presumed that
it may be possible to meet
it out of the grant already
placed at the disposal
of the Dept in connection
with the Viceregal visit
2/ 8/12 may be sanctd Draft
Jointly is put up
Dewan)
Cab 8/12
V
11/12
Cab

109.

To

The Private Secretary to H.H. the Maharaja
Chief Electrical Engineer of Mysore.
Comptroller, Mysore Government.
No. G. 9587-9/ 12-12-23
Sanctioning the estimates for providing
8 wall plugs in the passage between
the Banqueting Hall, and the Guest Room

NOTE—Contn. sheet.

3534 (3

G. R. S. III-21

General and Revenue Secretariat. | V.V. File No. 4 of 1923

Serial No.

at Mysore for replacing the burnt out lamps and effecting alterations in the various buildings at Kavaipur, and for erecting and installing bell bells from Viceroys room to his Valets tent and from Vicerine room to her maids appartments in Kavaipur.

NOTE—Contn. sheet.

18518

G.M. 3533/4

GOVERNMENT OF MYSORE

ELECTRICAL DEPARTMENT

—o—

OFFICE OF THE CHIEF ELECTRICAL ENGINEER,

Bangalore, 3rd December 1923.

(MYSORE; INDIA.)

IN REPLY REFER
No. 3625
Enclos. Nil One. Two

Telegraphic Address:
"GOMED"

Codes Used
Bentley's Lieber's
A. B. C. 6TH EDITION
BUSINESS TELEGRAPH CODE.

V.V. 4-23-106.

GENL. & REV. SECTT.
Br. G.M.
5 DEC. 1923
G. D. SECTION

The Chief Secretary
to the Government of
His Highness The Maharaja of Mysore,
BANGALORE.

Sir,

Installing eight wall plugs between the Banquet Hall and the small dining room of Government House, MYSORE.

With reference to G.O.No.G.197-9/VV 4-23-72, dated 28th October 1923, conveying sanction to the estimate amounting to Rs161/- for the above work, I have the honour to submit herewith a revised estimate amounting to Rs337/- for the same, duly countersigned by the Private Secretary to His Highness the Maharaja of Mysore, for favour of sanction at an early date.

2. A copy of the M.P.L. Superintendent's report, explaining the necessity for the revision, is also enclosed for information.

3. The original estimate sanctioned in the G.O. under reference may kindly be cancelled.

I have the honour to be,
Sir,
Your most obedient servant,

M Elayan

For Chief Electrical Engineer.

CSC-VJN.

(5

Report to accompany the revised estimate for installing eight wall plugs in the passage between Banquet Hall and the small dining room of the Government House, Mysore.

==========

The original idea was to supply current for the roasters and toasters from the 110 volts, 60 cycles distribution board as these appliances were of small capacity. It is now explained by the Government House, Superintendent, that big cooking ranges each taking about 15 amps: are also intended to be used from these wall plugs. As this heavy load is likely to affect the lighting system, it is proposed to supply 25 cycles current for these 8 wall plugs from the 10 K.V.A. Transformers that are already installed for supplying power to the hot cases. Provision will be made for putting up control switches and protecting fuses.

The switch board will be fixed up in the passage between the hot case room and the Banquet Hall. The 110 volts, 25 cycles mains from the transformers to the switch board willbe run in 1¼" conduit using No.4 B & S insulated wire.

At present, current for the heating appliances in the Heaters room is directly fed from the 10 K.V.A., 25 cycles, transformers. It is now arranged to fed these appliances from the new switch board which also supplies current for the wall plugs. For the sub mains, from the new switch board to the wall plugs, Henlev's lead covered twin cable No.10 S.W.G. will be used.

==========

Mysore, 29-10-22.
MSS-VRG.

Superintendent,
M.P.L.

Chief Elect Engr.

18517

G.M-3534 (6

IN REPLY REFER TO No. 3626 Enclo. 2

GOVERNMENT OF MYSORE

ELECTRICAL DEPARTMENT

—o—

OFFICE OF THE CHIEF ELECTRICAL ENGINEER,

Bangalore 4th December *192* 3.

(MYSORE, INDIA.)

Telegraphic Address:
"GOMED"

Codes Used
Bentley's Lieber's
A. B. C. 6TH EDITION
BUSINESS TELEGRAPH CODE.

The Chief Secretary to the Govt. of

His Highness the Maharaja of Mysore,

Bangalore.

V.V.H-23-107

GENL. & REV. SECTT. Br. G.M 5. DEC. 1923 G. D. SECTION

Sir,

Replacing the burnt out lamps and attending to the alterations in the various buildings at Karapur.

I have the honour to forward the enclosed estimate amounting to Rs.187/- for the above work duly counter-signed by the Huzur Secretary to His Highness the Maharaja of Mysore, for favour of communicating sanction under "Viceregal Reception charges".

2. A copy of the report accompanying the estimate is also enclosed for information.

I have the honour to be,

Sir,

Your most obedient servant,

M Devan

CSC-AK.

Chief Electrical Engineer.

Report to accompany the estimate for replacing the burnt out lamps and attending to the alterations in the various buildings at Karapur.

As most of the lamps in Her Highness the Maharany's building and Viceroy lodge at Karapur are burnt out and so more lamps are required for renewals during the stay of the party, this estimate is prepared for the required number of lamps and it also provides for shifting the position of the 2 electroliers in Her Highness the Maharan building, as per requirements furnished by the Assistant Engineer in charge of the Buildings at Karapur.

Superintendent,
Mysore Power and Light.
10/11/20

CRG-CNR.

for Chief Elect Engr
3/12
3/12

13516

G.W. 3530/8

IN REPLY REFER TO
No. 3627
Enclo. 2

GOVERNMENT OF MYSORE

ELECTRICAL DEPARTMENT

—— o ——

OFFICE OF THE CHIEF ELECTRICAL ENGINEER,

Telegraphic Address:
"GOMED"

Codes Used
Bentley's Lieber'
A. B. C. 6TH EDITION
BUSINESS TELEGRAPH CODE.

Bangalore 4th December 1923.
(MYSORE, INDIA.)

E.V. 4-23-108.

The Chief Secretary to Govt.
of His Highness the Maharaja of Mysore,
Bangalore.

Sir,

GENL. & REV. Br. 5 DEC. 1923 D. SECTION

Wiring and installing call bells from Viceroy's room to His Valet's tent and from Vicerine room to Her Maid's appartments in Karapur.

I have the honour to forward the enclosed estimate amounting to Rs45/- for the above work, duly countersigned by the Private Secretary to His Highness the Maharaja of Mysore, for favour of sanction under "viceregal Reception charges"

A copy of the report accompanying the estimate is also enclosed for information.

I have the honour to be,

Sir,

Your most obedient servant,

M Devaya

Chief Electrical Engineer.

CSC-AK.

(9

Report to accompany the estimate for installing Call Bells in Viceroy s Lodge in Karapur.

As per instructions from the Private Secretary to His ness the Maharaja of Mysore, this estimate is prepared for providing call bells from the viceroy's Room to his valet's and 2 bell from the Vicerine to her two maids' apartments in Karapur. The push button from the vicerine room is arranged to be fixed to her cot and trust that this will have the approval of the Private Secretary.

If any little changes are requied, the same will be attended to later.

Superintendent,
Mysore Power and Light.

RVP-CNR.

3/12

Chief Electrical Engineer.

10

G.R.S. VI-71]

SUBJECT.....

.....

.....

Diary No. of letter replied to.....

General and Revenue Secretariat

( )'

, *the* 191

Date of issue 12/12/23

Signed by Mr. C.S.K

May this be

i Printed?

ii treated as a standing order?

iii published in the Gazette English part?

iv translated?

v placed at the disposal of the press;

vi published in the Gazette Kannada part?

Section VV.

File No. 4-23

Serial No. 168

Proceedings of the Government of His Highness the Maharaja of Mysore.

Read.— G.O. No. G 195-9/VV 4-23-72 dated 11th 28th October 1923, sanctioning an estimate amounting to Rs. 161/- for providing 8 wall lights in the passage between the Banqueting Hall and the small dining room of the Govt House at Mysore.

2. Letter No. 3625 dated the 4th December 1923

from the Chief Electrical Engr
forwarding for Sanction,
in supersession of the
estimate sanctioned in the
order read above, a revised
estimate amounting to Rs 3371/-

3. Letter No 3626, dated the
4th Decr 1923 from the ~~same~~ above
officer forwarding for
sanction an estimate
amounting to Rs 157/-
for replacing the burnt
out lamps and effecting
the alterations in the
various buildings at
Kamptee.

4. Letter No 3627 dated the
4th instt from the same
officer forwarding for
sanction an estimate
for Rs 467- for wiring
and installing call bells
from Viceroy's room to
Valets ~~room~~ tent- and from

List of enclosures.

Copied by

Examined by

G.R, S. 27]

GENERAL AND REVENUE SECRETARIAT.

(*Continuation sheet draft form.*)

3 (12

Viceroy's room to Lieut Thaiss
appointments in Manipur

Order Ltr 9587-9/
8/12-12-23
The estimates
rec'd to date are
sanctioned. The cost
will be met out of
the special grant
sanctioned in G.O.
Ltr G.T-9/V.V.4-23-64
dated the 17th October
1923.

Baly
8/12
Chief Secy
to Govt

To The Private Secy to H
The Chief Electrical
Engineer with the
estimates

The Comptroller